

<b>Quotation Number:</b>	<b>RFQ202010/009</b>
<b>Description:</b>	<b>SUPPLY AND DELIVERY OF 3 FIRE EXTINGUISHERS TO DAVEYTON WCW</b>
<b>Bid Closing Date:</b>	19 October 2020 @12pm
<b>Compulsory Briefing Session:</b>	N/A
<b>Plant Address:</b>	Plot 44 Laris street Etwatwa Extension 1
<b>Contact Person</b>	Andriette Jacobs
<b>Contact Number</b>	0822643136
<b>Validity period</b>	3 days

#### **REQUEST FOR RFQ:**

#### **SUPPLY AND DELIVERY OF 3 FIRE EXTINGUISHERS FOR DAVEYTON**

---

#### ***Quotation Requirements:***

Supply and Delivery of three (3) 9 Kg handheld Dry chemical Powder (DCP) fire extinguishers.

Service date should not be older than one month.

Extinguishers should be compliant to SABS standards.

Should also conform to the minimum fire ratings as specified in SANS1910:2009.

Each extinguisher should be fitted with a high pressure discharge hose and discharge nozzle.

Should be suitable for Class A (Combustible materials), B (Flammable or combustible liquids) and C (Electrical) fires.

The Dial on the gauge must point on the green indicating that the extinguisher is sufficiently charged.

Wall mounting should also be included.

Expiry date: 1 Year

Warranty: 1 Year

Extinguishers should be refillable.

Working pressure: 1400kPa

Test pressure: 2100kPa

Burst Pressure: > 5500kPa

Safety valve: +/- 2200kPa

**PLEASE NOTE THAT FAILURE TO MEET ANY OR ALL OF THESE REQUIREMENTS WILL LEAD TO DISQUALIFICATION**

- BBBEE Compliance Certificate
- Valid Original Tax Pin Certificate
- Copy of Latest Municipal Account or Lease Agreement
- Declaration of Interest (MBD4) - (Download form ERWAT website/Procurement/MBD Forms)

#### **GENERAL NOTES**

---

All RFQ's must be e-mailed to: [rfq@erwat.co.za](mailto:rfq@erwat.co.za)